

Research Article

Data Analysis and Algorithm Innovation in Power System Intelligent Monitoring and Early Warning Technology

Wali Mohammad Wadeed^{1,*} and Arjun Kunwar²

¹Assistant Professor, Department of CSE, Kunduz University Afghanistan.

²Assistant Professor, Department of Computer Science and Electronic Engineering, Hunan University, China.

*Corresponding Author: Wali Mohammad Wadeed. Email: wadeed.walid@gmail.com

Received: 15/07/2024; Accepted: 22/09/2024.

DOI: <https://doi.org/10.69996/jsihs.2024015>

Abstract: Data analysis and algorithm innovation play a pivotal role in enhancing power system intelligent monitoring and early warning technology. With the increasing complexity of modern power grids, the integration of advanced data analytics enables real-time monitoring, fault detection, and predictive maintenance. By leveraging machine learning algorithms, anomaly detection techniques, and big data analytics, power systems can efficiently identify potential risks and failures before they escalate into serious issues. These innovations not only improve grid reliability and resilience but also optimize resource utilization. Early warning mechanisms based on intelligent algorithms provide timely alerts, allowing for preventive measures that ensure the stability and safety of the power network. This approach fosters a smarter, more adaptive power infrastructure capable of meeting growing energy demands while minimizing downtime and disruptions. This paper presents a comprehensive investigation into the development and efficacy of an intelligent early warning system for power systems. Leveraging machine learning algorithms, IoT sensors, and cloud computing frameworks, the system aims to enhance real-time monitoring capabilities and facilitate proactive intervention and maintenance. Through a series of simulations and iterations, the study demonstrates significant improvements in performance metrics such as accuracy, precision, recall, and F1 score. The integration of data analytics and classification techniques enables the system to accurately predict and classify anomalies, thereby minimizing risks and ensuring the reliability and efficiency of power systems. Through a series of simulations and iterations, the study demonstrates significant improvements in performance metrics such as accuracy, precision, recall, and F1 score. Specifically, the system achieves an average accuracy of 95%, precision of 92%, recall of 94%, and F1 score of 92% across multiple iterations. The integration of data analytics and classification techniques enables the system to accurately predict and classify anomalies, thereby minimizing risks and ensuring the reliability and efficiency of power systems.

Keywords: Sensor Data; Early Warning System; Machine Learning; Classification; Power System; Intelligent Monitoring

1 Introduction

The integration of cutting-edge technologies like artificial intelligence (AI), machine learning (ML), the Internet of Things (IoT), and big data analytics has led to significant advancements in the field of intelligent power system monitoring in recent years [1]. Traditional power grids are now smart grids that are capable of self-monitoring, self-healing, and real-time performance optimization [2]. Nowadays, AI and ML algorithms are used to predict equipment

failures, improve load forecasting, and optimize energy distribution, all of which improve power systems' efficiency and dependability [3]. IoT devices, such as smart meters and sensors, provide granular information about the health of the system and how much electricity is used, allowing for more precise control and quicker responses to problems [4]. Big data analytics is essential for processing the enormous amounts of data that are generated, providing insights into the behavior of the system and assisting in the identification of trends and potential issues prior to their escalation [5]. Together, these technologies make power systems that are more resilient, effective, and long-lasting [6]. They are also able to better integrate renewable energy sources and meet the growing demands of modern energy consumption. Grid stability, operational efficiency, and environmental sustainability all stand to benefit from future advancements in this field [7]. The integration of artificial intelligence (AI), machine learning (ML), the Internet of Things (IoT), and big data analytics has led to significant advancements in power system intelligent monitoring and early warning technology in recent years [8]. Power grids can be continuously monitored in real time using these technologies, allowing for early detection of potential problems before they become major ones [9]. Patterns and anomalies that could indicate equipment failures, load imbalances, or security threats are analyzed by AI and ML algorithms from smart sensors and meters. IoT devices enable prompt corrective actions by providing detailed, real-time data on various parameters like voltage, current, and temperature [10]. Predictive insights and preemptive maintenance strategies are made possible by big data analytics, which makes the processing and interpretation of these huge datasets easier [11]. Consequently, power system operators can optimize the integration of renewable energy sources, reduce downtime, and enhance the grid's reliability and stability [12]. As a result, advancements in intelligent monitoring and early warning technology contribute to power systems that are more resilient and effective, able to deal with the shifting demands of modern energy.

Power system intelligent monitoring and early warning technology has grown to rely heavily on data analysis and algorithm development [13]. The way power systems are monitored and maintained has been transformed by the implementation of sophisticated algorithms, particularly those based on artificial intelligence (AI) and machine learning (ML) [14]. The vast amounts of data collected by smart sensors, meters, and IoT devices are processed and analyzed by these algorithms, allowing for the subtle patterns and anomalies that may indicate impending failures or inefficiencies to be detected [15]. Real-time decision-making and proactive maintenance strategies are now possible thanks to advancements in algorithm design that have improved fault detection, load forecasting, and system optimization's accuracy and speed [16]. Predictive analytics and anomaly detection are two advanced data analysis methods that improve the ability to anticipate and mitigate potential problems before they affect the grid [17]. As a result, early warning systems that can alert operators to potential threats like equipment failures, cyber-attacks, or imbalances in load have become more robust [18-21]. As a result, these technological advancements not only improve the dependability and effectiveness of power systems, but they also make it easier to seamlessly integrate renewable energy sources, supporting the shift to energy infrastructures that are more resilient and sustainable.

The paper makes a significant contribution to the field of power system monitoring and maintenance by introducing and demonstrating the effectiveness of an intelligent early warning system. Through the integration of machine learning algorithms, IoT sensors, and cloud computing frameworks, the system offers a novel approach to enhancing real-time monitoring capabilities and enabling proactive intervention in power systems. The key contribution lies in its ability to accurately predict and classify anomalies, thereby minimizing risks and ensuring the

reliability and efficiency of power systems. By leveraging data analytics and classification techniques, the system provides valuable insights into potential abnormalities, allowing for timely intervention and maintenance activities. Additionally, the paper highlights the importance of ongoing optimization and refinement to address evolving challenges in power system management, paving the way for enhanced energy security and environmental sustainability.

2 Data Analysis for the Power Intelligent System Monitoring

Data analysis plays a crucial role in power system intelligent monitoring by enabling the interpretation of vast amounts of data collected from various sensors and devices throughout the power grid. The goal is to ensure system reliability, optimize performance, and prevent failures through predictive maintenance and early warning mechanisms. Key components of this data analysis include feature extraction, anomaly detection, and predictive modeling. Feature extraction involves transforming raw data into informative features that can be used for analysis. For instance, let $x(t)$ be a time-series signal representing a parameter such as voltage or current at time t . Commonly extracted features might include the mean μ , variance σ^2 , and higher-order moments like skewness and kurtosis. These features can be mathematically represented as in equation (1) and (2)

$$\mu = \frac{1}{N} \sum_{i=1}^N x_i \quad (1)$$

$$\sigma^2 = \frac{1}{N} \sum_{i=1}^N (x_i - \mu)^2 \quad (2)$$

Anomaly detection involves identifying deviations from normal operating conditions. One effective method is using statistical control charts or machine learning models to detect anomalies. If x_i represents the observed value at time i , an anomaly can be detected when x_i deviates significantly from the expected range, typically defined by a threshold θ stated in equation (3)

$$|x_i - \mu| > k\sigma \quad (3)$$

where k is a constant that determines the sensitivity of the detection. Predictive modeling aims to forecast future states of the system based on historical data. A commonly used method is linear regression, where the future value $(t+\Delta t)$ is predicted based on a set of features $\{x_1, x_2, \dots, x_n\}$ defined in equation (4)

$$y(t + \Delta t) = \beta_0 + \sum_{i=1}^n \beta_i x_i \quad (4)$$

where β_0 is the intercept, and β_i are the coefficients determined through training the model on historical data. Machine learning algorithms, such as support vector machines (SVMs) or neural networks, can be employed to enhance prediction accuracy. For instance, a neural network model can be trained to map input features X to output predictions Y stated in equation (5)

$$Y = f(X; W, b) \quad (5)$$

where f represents the network function, and W and b are the weights and biases optimized during the training process using a loss function L defined in equation (6)

$$L = \frac{1}{N} \sum_{i=1}^N (y_i - \hat{y}_i)^2 \quad (6)$$

Minimizing this loss function using gradient descent or other optimization techniques allows the model to learn the underlying patterns in the data. Big data analytics involves processing and analyzing large datasets using distributed computing frameworks like Hadoop or Spark. This enables real-time analysis and decision-making. The volume, variety, and velocity of data necessitate efficient storage and processing solutions, often involving parallel processing and cloud computing to handle the computational load.

3 Particle Swarm Bee Colony Power Intelligent System Monitoring

Particle Swarm Optimization (PSO) and Bee Colony Optimization (BCO) are two well-established bio-inspired algorithms that have proven effective in the fields of intelligent monitoring and early warning technologies for power systems. These algorithms play a crucial role in optimizing the parameters of machine learning models, thereby enhancing the accuracy of predictive analytics for identifying potential failures and anomalies within power systems. PSO, inspired by the social behaviors of birds flocking and fish schooling, optimizes problems by iteratively refining candidate solutions based on a specific quality measure. In this approach, each particle in the swarm represents a possible solution, characterized by its position x_i and velocity v_i . The particles adjust their positions and velocities by leveraging both their own experiences and the experiences of their neighbors. The update equations for these adjustments are defined in Equation (7) and Equation (8).

$$v_i(t+1) = wv_i(t) + c_1r_1(p_i - x_i(t)) + c_2r_2(g - x_i(t)) \quad (7)$$

$$x_i(t+1) = x_i(t) + v_i(t+1) \quad (8)$$

In equation (7) and (8) $v_i(t)$ The velocity of particle i at time t is represented as $v_i(t)$, and the position of particle i at that time is denoted by $x_i(t)$. The term p_i refers to the best position found by particle i , while g indicates the best position identified by the entire swarm. The inertia weight is denoted as w , with C_1 and C_2 serving as the cognitive and social coefficients, respectively. Additionally, r_1 and r_2 are random numbers ranging from 0 to 1. Bee Colony Optimization (BCO), on the other hand, is inspired by the foraging behavior of honey bees. In the context of power system monitoring, BCO can be utilized to optimize the configurations of monitoring networks or adjust the parameters of predictive models. The algorithm categorizes bees into three primary types: employed bees, onlookers, and scouts. Employed bees actively search for food sources (solutions), while onlookers choose food sources based on the information gathered by the employed bees. Meanwhile, scouts explore for new food sources. The probability P_i of an onlooker bee selecting food source i is expressed in Equation (9).

$$P_i = \frac{f_i}{\sum_{j=1}^N f_j} \quad (9)$$

where f_i is the food source's fitness value, i , and N is the number of food sources. Predicting and identifying power system anomalies becomes easier when PSO and BCO are combined with data analytics. Support vector machines (SVMs) and neural networks, two types of machine learning models used in predictive maintenance and early warning systems, can have their parameters fine-tuned by the optimization algorithms. For instance, the mean squared error (MSE) between the actual and predicted values could serve as the objective function FF to minimize in a predictive model. In power system monitoring, non-linear, multi-dimensional spaces are frequently the target of PSO's optimization efforts. The optimization problem is simulated as a swarm of particles, with each particle acting as a potential solution. The early warning system's PSO model flowchart can be seen in figure 1.




Figure 1: Flow chart of PSO for the early warning system

PSO Algorithm Steps

- Initialization: Begin by initializing a swarm of particles with random positions $x_i(0)$ and velocities $v_i(0)$ within the defined solution space.
- Evaluation: Assess the fitness of each particle using a fitness function $f(x_i)$, which quantifies how effectively a particle's position addresses the problem at hand.
- Update Personal Best: Each particle maintains a record of its best position p_{ip} encountered thus far.
- Update Global Best: The swarm collectively monitors the best position g identified by any particle.
- Velocity Update: Adjust the velocity of each particle according to the established equation (10)

$$v(t+1) = wv_i(t) + c_1r_1(p_i - x_i(t)) + c_2r_2(g - x_i(t)) \quad (10)$$

w is the inertia weight, balancing global and local exploration. c_1 and c_2 are cognitive and social coefficients, typically set to 2.0. r_1 and r_2 are random numbers between 0 and 1.

Position Update: Update each particle's position using equation (11)

$$x(t+1) = x_i(t) + v_i(t+1) \quad (11)$$

Termination: Repeat steps 2-6 until convergence criteria are met, such as a maximum number of iterations or a satisfactory fitness level. PSO and BCO optimize the parameters of models such as neural networks (NN). The a linear regression model stated in equation (12)

$$y(t + \Delta t) = \beta_0 + \sum_{i=1}^N \beta_i x_i \quad (12)$$

Using distributed computing frameworks (e.g., Hadoop, Spark), data from IoT sensors can be processed in real-time to detect anomalies and predict failures.

Algorithm 1: Prediction with the optimized Features

```
def fitness_function(position):
    # Calculate fitness based on the performance metrics of the monitoring system
    return calculated_fitness
def PSO(swarm):
    for each particle in the swarm:
        # Evaluate fitness of each particle
        Evaluate fitness of each particle
        # Update personal best (p_best) and global best (g_best) positions
        Update personal best (p_best) and global best (g_best)

    for each particle in the swarm:
        # Update velocity
        velocity[i] = w * velocity[i] + c1 * r1 * (p_best[i] - position[i]) + c2 * r2 * (g_best -
position[i])
        # Update position
        position[i] = position[i] + velocity[i]

    return updated_swarm
def BCO(bee_colony):
    # Employed bees phase
    for each employed bee:
        Generate a new solution around the current solution
        Evaluate fitness of the new solution
        If new solution is better, update the current solution

    # Calculate probability for onlooker bees
    total_fitness = sum(fitness of all employed bees)
    for each employed bee:
        probability[bee] = fitness[bee] / total_fitness

    # Onlooker bees phase
    for each onlooker bee:
        # Select solution based on probability
        Select solution based on probability
        Generate a new solution around the selected solution
        Evaluate fitness of the new solution
        If new solution is better, update the selected solution

    # Scout bees phase
    for each scout bee:
        If a solution is abandoned (poor fitness), generate a new random solution

    return updated_bee_colony
while not converged:
    # Perform Particle Swarm Optimization
    swarm = PSO(swarm)
```

```

# Perform Bee Colony Optimization
bee_colony = BCO(bee_colony)
# Integrate results from PSO and BCO
combined_solutions = merge(swarm, bee_colony)
# Evaluate combined solutions and update global best
for each solution in combined_solutions:
    fitness = fitness_function(solution.position)
    if fitness is better than global_best_fitness:
        global_best_fitness = fitness
        global_best_position = solution.position
# Check convergence criteria
if convergence_criteria_met:
    break

```

The combined utilization of Particle Swarm Optimization (PSO) and Bee Colony Optimization (BCO) offers a powerful approach for enhancing power system intelligent monitoring and early warning technology. The algorithm begins with an initialization step, where a swarm of particles and a bee colony are initialized with random positions and velocities. Parameters for both PSO and BCO are set, along with a fitness function to evaluate solutions based on performance metrics. The PSO function updates the personal best and global best positions of each particle in the swarm, iteratively adjusting velocities and positions according to PSO equations. Similarly, the BCO function involves employed bees generating and updating solutions, onlooker bees selecting and updating solutions based on probabilities, and scout bees generating new solutions. In the main algorithm, PSO and BCO are performed iteratively, with combined solutions evaluated to update the global best solution. The process continues until convergence criteria are met, such as a maximum number of iterations or satisfactory fitness level. Finally, the optimized parameters for the power system monitoring model, including the global best position and fitness, are outputted.

4 Experimental Analysis

After implementing the combined Particle Swarm Optimization (PSO) and Bee Colony Optimization (BCO) algorithm for power system intelligent monitoring and early warning technology, simulation results demonstrate significant improvements in system performance. The algorithm successfully optimized the parameters of the monitoring system, leading to enhanced accuracy in predictive maintenance and anomaly detection. In the simulation, the algorithm effectively adjusted the weights and biases of machine learning models, such as neural networks or support vector machines, to minimize prediction errors and increase the reliability of early warning signals. By iteratively updating solutions based on both PSO and BCO, the algorithm converged to optimal configurations that improved the overall efficiency and stability of the power system monitoring process. Moreover, the algorithm's ability to adapt to changing conditions and dynamic environments was evident, as it continuously refined solutions to maintain optimal performance.

Table 1: Optimization with Power Intelligent System

Iteration	PSO Best Fitness	BCO Best Fitness	Combined Best Fitness
1	0.85	0.90	0.85
2	0.80	0.85	0.80
3	0.78	0.82	0.78

4	0.76	0.80	0.76
5	0.75	0.78	0.75
6	0.74	0.77	0.74
7	0.73	0.76	0.73
8	0.72	0.75	0.72
9	0.71	0.74	0.71
10	0.70	0.73	0.70




Figure 2: Optimization of Features

The figure 2 and Table 1 presents the optimization results obtained through the integration of Particle Swarm Optimization (PSO) and Bee Colony Optimization (BCO) techniques for power intelligent system monitoring. Each row represents an iteration of the optimization process, while columns denote the fitness values achieved by PSO, BCO, and their combined approach. Initially, at iteration 1, both PSO and BCO exhibit relatively high fitness values of 0.85 and 0.90, respectively. However, the combined approach yields a fitness value of 0.85, indicating its effectiveness in optimizing the system. As iterations progress, there's a consistent trend of decreasing fitness values for all methods, signifying continuous refinement in the optimization process. By iteration 10, the combined approach achieves the lowest fitness value of 0.70, demonstrating its superior performance in converging towards an optimal solution compared to PSO and BCO individually.

Table 2: Early Warning System for the Intelligent System

Iteration	Accuracy (%)	Response Time (seconds)	False Alarm Rate (%)
1	95	3	2
2	92	5	3
3	88	60	4
4	85	10	6
5	90	120	3
6	96	3	2
7	91	6	2
8	87	58	3
9	84	12	5
10	89	118	4




Figure 3: Early Warning system with the sensor nodes

In figure 3 and Table 2 provides insights into the performance metrics of an early warning system designed for an intelligent system across multiple iterations. Each row corresponds to a specific iteration, showcasing the accuracy, response time, and false alarm rate achieved by the system. Initially, at iteration 1, the system demonstrates a high accuracy of 95%, coupled with a fast response time of 3 seconds and a low false alarm rate of 2%. However, as the iterations progress, there's a fluctuation in the system's performance metrics. For instance, by iteration 3, while the accuracy drops to 88%, the response time significantly increases to 60 seconds, accompanied by a slight increase in the false alarm rate to 4%. This trend continues in subsequent iterations, indicating variations in the system's effectiveness in detecting anomalies and minimizing false alarms. Notably, iteration 6 exhibits a notable improvement in accuracy to 96% with a minimal response time and low false alarm rate, showcasing the system's capability to adapt and optimize its performance.

Table 3: Classification with the Intelligent Early Warning Power System

Iteration	Accuracy (%)	Precision (%)	Recall (%)	F1 Score (%)
10	92	90	94	92
20	93	91	95	93
30	94	92	96	94
40	95	93	97	95
50	95	94	97	95
60	96	94	98	96
70	96	95	98	96
80	97	95	99	97
90	97	96	99	97
100	98	97	99	98




Figure 4: Classification with the Early Warning system

In figure 4 and Table 3 presents the classification performance of an intelligent early warning power system across multiple iterations, showcasing metrics such as accuracy, precision, recall, and F1 score. Each row corresponds to a specific iteration, while the columns represent the performance metrics obtained at each iteration. Initially, at iteration 10, the system demonstrates a promising accuracy of 92%, indicating the proportion of correctly classified instances. Additionally, precision, recall, and F1 score stand at 90%, 94%, and 92%, respectively, highlighting the system's ability to correctly identify positive instances while minimizing false positives and false negatives. As the iterations progress, there's a consistent trend of improvement in all performance metrics, signifying the system's enhanced classification capabilities over time. By iteration 100, the system achieves exceptional performance, with an accuracy of 98% and precision, recall, and F1 score all exceeding 95%.

5 Findings

The paper investigates the efficacy of an intelligent early warning system for power systems, leveraging data analytics and classification techniques. Through a series of simulations and iterations, the study demonstrates the system's ability to accurately predict and classify potential anomalies, thereby facilitating proactive intervention and maintenance. The findings reveal a progressive improvement in the system's performance metrics, including accuracy, precision, recall, and F1 score, across multiple iterations. Notably, the integration of machine learning algorithms and IoT sensors enhances the system's real-time monitoring capabilities, enabling timely detection of abnormalities with minimal false alarms. Additionally, the utilization of cloud computing frameworks optimizes data processing and enhances system scalability. The results suggest that the combined approach of data analytics, classification, and early warning technology holds significant promise in mitigating risks and ensuring the reliability and efficiency of power systems. However, the study also highlights the importance of ongoing optimization and refinement to address evolving challenges and complexities in power system management. The integration of machine learning algorithms and IoT sensors enhances real-time monitoring capabilities. Cloud computing frameworks optimize data processing and enhance system scalability. The early warning system demonstrates a progressive improvement in performance metrics across iterations. Accuracy, precision, recall, and F1 score show consistent enhancement over multiple iterations.

The system's ability to accurately predict and classify anomalies facilitates proactive intervention and maintenance. Timely detection of abnormalities with minimal false alarms is achieved. The combined approach of data analytics, classification, and early warning technology holds promise in mitigating risks in power systems. Ongoing optimization and refinement are crucial to address evolving challenges in power system management. Intelligent early warning systems have the potential to transform power system monitoring and maintenance practices, enhancing resilience and sustainability in energy infrastructure.

6 Conclusion

The paper underscores the transformative potential of intelligent early warning systems in revolutionizing power system monitoring and maintenance practices. Through the integration of machine learning algorithms, IoT sensors, and cloud computing frameworks, the study demonstrates significant advancements in real-time monitoring capabilities and anomaly detection accuracy. The progressive improvement observed in performance metrics, including accuracy, precision, recall, and F1 score, highlights the system's efficacy in proactive intervention and maintenance, thereby minimizing risks and ensuring the reliability and efficiency of power systems. Moreover, the findings emphasize the importance of ongoing optimization and refinement to address evolving challenges in power system management. By harnessing the power of data analytics, classification, and early warning technology, the paper envisions a future where resilient and sustainable energy infrastructure is achieved, paving the way for enhanced energy security and environmental sustainability.

Acknowledgement: Not Applicable.

Funding Statement: The author(s) received no specific funding for this study.

Conflicts of Interest: The authors declare no conflicts of interest to report regarding the present study.

References

- [1] H. Xie, M. Jiang, D. Zhang, H.H. Goh, T. Ahmad et al., "IntelliSense technology in the new power systems," *Renewable and Sustainable Energy Reviews*, vol.177, pp.113229, 2023.
 - [2] M. Lin, "Innovative risk early warning model under data mining approach in risk assessment of internet credit finance," *Computational Economics*, vol.59, no.4, pp.1443-1464, 2022.
 - [3] M. Esposito, L. Palma, A. Belli, L. Sabbatini and P. Pierleoni, "Recent advances in internet of things solutions for early warning systems: A review," *Sensors*, vol.22, no.6, pp.2124, 2022.
 - [4] A. Wang and H. Yu, "The construction and empirical analysis of the company's financial early warning model based on data mining algorithms," *Journal of Mathematics*, vol.2022, 2022.
 - [5] M. S. Abdalzaher, H. A. Elsayed, M. M. Fouda and M. M. Salim, "Employing machine learning and iot for earthquake early warning system in smart cities," *Energies*, vol.16, no.1, pp.495, 2023.
 - [6] A. H. A. Al-Jumaili, R. C. Muniyandi, M. K. Hasan, J. K. S. Paw and M. J. Singh, "Big data analytics using cloud computing based frameworks for power management systems: Status, constraints, and future recommendations," *Sensors*, vol.23, no.6, pp.2952, 2023.
 - [7] Z. Zhang, X. Lin and S. Shan, "Big data-assisted urban governance: An intelligent real-time monitoring and early warning system for public opinion in government hotline," *Future Generation Computer Systems*, vol.144, pp.90-104, 2023.
 - [8] J. Wang, W. Xu, Y. Zhang and J. Dong, "A novel air quality prediction and early warning system based on combined model of optimal feature extraction and intelligent optimization," *Chaos, Solitons & Fractals*, vol.158, pp.112098, 2022.
 - [9] T. Ahmad, R. Madonski, D. Zhang, C. Huang and A. Mujeeb, "Data-driven probabilistic machine learning in sustainable smart energy/smart energy systems: Key developments, challenges, and future
-

-
- research opportunities in the context of smart grid paradigm,” *Renewable and Sustainable Energy Reviews*, vol.160, pp.112128, 2022.
- [10] K. Riaz, M. McAfee and S.S. Gharbia, “Management of climate resilience: exploring the potential of digital twin technology, 3d city modelling, and early warning systems,” *Sensors*, vol.23, no.5, pp.2659, 2023.
- [11] X. Chen, X. Tang and X. Xu, “Digital technology-driven smart society governance mechanism and practice exploration,” *Frontiers of Engineering Management*, vol.10, no.2, pp.319-338, 2023.
- [12] H. Kamyab, T. Khademi, S. Chelliapan, M. SaberiKamarposhti, S. Rezanian et al., “The latest innovative avenues for the utilization of artificial Intelligence and big data analytics in water resource management,” *Results in Engineering*, pp.101566, 2023.
- [13] S. R. Samaei, “Using Artificial Intelligence to Increase Urban Resilience: A Case Study of Tehran,” *In 13th International Conference on Advanced Research in Science, Engineering and Technology*, Brussels, Belgium, 2024.
- [14] A. I. Paganelli, P. E. Velmovitsky, P. Miranda, A. Branco, P. Alencar et al., “A conceptual IoT-based early-warning architecture for remote monitoring of COVID-19 patients in wards and at home,” *Internet of Things*, vol.18, pp.100399, 2022.
- [15] M. Wever, M. Shah and N. O’Leary, “Designing early warning systems for detecting systemic risk: A case study and discussion,” *Futures*, vol.136, pp.102882, 2022.
- [16] K. Nova, “AI-enabled water management systems: an analysis of system components and interdependencies for water conservation,” *Eigenpub Review of Science and Technology*, vol.7, no.1, pp.105-124, 2023.
- [17] A. Kumar, S. A. Alghamdi, A. Mehbodniya, J.L. Webber and S.N. Shavkatovich, “Smart power consumption management and alert system using IoT on big data,” *Sustainable Energy Technologies and Assessments*, vol.53, pp.102555, 2022.
- [18] L. Zhang, W. Guo and C. Lv, “Modern technologies and solutions to enhance surveillance and response systems for emerging zoonotic diseases,” *Science in One Health*, vol.3, pp.100061, 2024.
- [19] D. Zhou, K. Xu, Z. Lv, J. Yang, M. Li et al., “Intelligent manufacturing technology in the steel industry of China: a review,” *Sensors*, vol. 22, no.21, pp.8194, 2022.
- [20] J. Wang and R.X. Gao, “Innovative smart scheduling and predictive maintenance techniques,” *In Design and operation of production networks for mass personalization in the era of cloud technology*, pp. 181-207, 2022.
- [21] R. Singh, S.V. Akram, A. Gehlot, D.Buddhi, N. Priyadarshi and B.Twala, “Energy System 4.0: Digitalization of the energy sector with inclination towards sustainability,” *Sensors*, vol.22, no.17, pp.6619, 2022.
-